

1. Unique identification of product	<b>Firetect® Flex strip</b>	
2. Intended use	service closure for structural (expansion) joints, to form a penetration seal in case of fire to reinstate the fire resistance of:  - standard flexible or rigid walls $\geq$ 100mm - standard rigid floors $\geq$ 150mm	
3. Manufacturer	KLF Building Products BV Techniekweg 11, 4207 HC Gorinchem, The Netherlands	
4. Authorised representative	not applicable	
5. System of AVCP	System 1	
6a. Harmonised standard	not applicable	
Notified body	not applicable	
6b. European Assessment Document (EAD)	ETAG 026-3	
European Technical Assessment (ETA)	<a href="#">ETA-15/0630</a>	
Technical Assessment Body (TAB)	SKG-IKOB	
Identification notified body	no. 0957	
7. Declared performances		
	<b>basic requirements</b>	<b>characteristics</b>
	<b>performances</b>	
	<b>BWR 1 Mechanical resistance and stability</b>	not applicable
	<b>BWR 2 Safety in case of fire</b>	
	EN 13501-1	reaction to fire
	EN 13501-2	resistance to fire
		field of application
		Class F
		per tested assembly; EI 30 up to EI 90, see ANNEX BWR2
	<b>BWR 3 Hygiene, health and environment</b>	
	EN 1026	air permeability
	ETAG 026-3, Annex C	water permeability
	declaration of manufacturer (DoP)	release of dangerous substances
		IA1, S/W3
		npd
		npd
		no release of dangerous substances
	<b>BWR 4 Safety in use - EOTA TR001</b>	
	mechanical resistance and stability	npd
	resistance to movement	npd
	adhesion	npd
	<b>BWR 5 Protection against noise</b>	
	EN 10140-2, EN ISO 717-1	airborne sound insulation
		npd
	<b>BWR 6 Energy, economy and heat retention</b>	
	EN 12664, EN 12667, EN 12939	thermal properties
	EN ISO 12572, EN 12056	water vapour permeability
		npd
	<b>General aspects relation to fitness for use</b>	
	ETAG 026-2, Annex B, B.6.2	durability and serviceability
		assumed working life for the intended use
		Z <sub>2</sub> (internal use)
		10 years
8. Specific Technical Documentation	not applicable	npd= no performance determined

The performances of the products identified are in conformity with the declared performances. This declaration of performance is issued, in accordance with Regulation 305/2011, under the sole responsibility of the manufacturer.

Signed for and on behalf of the manufacturer in Gorinchem on October 2 2017 by C. Buikema



field of application (FoA)	Firetect <sup>®</sup> Flex strip
	tested and certified by ETA-15/0630; fire resistance performances and assembly methods for uses in:

<b>constructive element</b> <sup>1)</sup>	
<b>fire rated walls</b> acc. EN 1363-1	<ul style="list-style-type: none"> <li>- standard flexible walls ≥ 100mm: 50mm MS profiles with on 2 sides min. 2x 12,5mm plaster board type F + insulation: rock wool ≥ 50mm, density ≥ 100 kg/m<sup>3</sup></li> <li>- standard rigid walls ≥ 100mm: blockwork, (aerated) concrete or masonry, density ≥ 650 kg/m<sup>3</sup></li> </ul>
<b>fire rated floors</b> acc. EN 1363-1	<ul style="list-style-type: none"> <li>- standard rigid floors ≥ 150mm: (aerated) concrete, density ≥ 650 kg/m<sup>3</sup></li> </ul>
<sup>1)</sup> the supporting construction must be classified acc. EN 13501-2 for the required fire resistance period	

<b>fire resistance</b>		
<b>field of application:</b>	acc. EN 13501-2 / 1366-4	
<table border="1" style="display: inline-table;"> <tr> <td>EI 30 up to EI 90: Flex strip</td> </tr> </table>	EI 30 up to EI 90: Flex strip	<b>structural joints:</b>
EI 30 up to EI 90: Flex strip		
- linear joints	≤ 50mm	

<b>fasteners</b>	- not applicable	see TDS
------------------	------------------	---------

<b>finish</b>	- seal remaining small gaps > 3mm with Acrylic or PA sealer	see TDS
---------------	---	---------

<b>product information</b>	
Product certification by DoP; more info on certification of CE building products through ETA at <a href="http://firetect.eu/certification">firetect.eu/certification</a>	
<ul style="list-style-type: none"> <li>- full DoP version: declaration of performance + chart field of application (FoA) + principle configurations; upon request</li> <li>- web DoP version: declaration of performance; other info can be downloaded at <a href="http://firetect.eu/download">firetect.eu/download</a></li> <li>- charts FoA: <a href="#">suitable product per type of fireseal + EI performance + product / joint details</a></li> <li>- TDS: <a href="#">general directions for use + product specs</a></li> </ul>	
Consult <a href="http://firetect.eu/download">firetect.eu/download</a> for updated versions; product development + fire tests are ongoing processes at KLF. Contact KLF for <b>other</b> EI requirements and (non)standard or complex site requirements; mail <a href="mailto:info@klf.nl">info@klf.nl</a>	
 	